Testing, and Research
Office: Sofia 1000, bul. „Al. Stamboliyski" 205, NIPRORUDA, building B, floor 2, office 233
Mobile: +359 878 112 112; e-mail: office@fplus-eu.com; www.fplus-eu.com

FPLUS
Изх.№ 508/31.07.2020

On 12.05.2020 a test of doors was performed according to European standard EN 1634-1: 2014 + A1: 2018.

The manufacturer of the single-leaf door type called **M BINALE"** is the company **CONF BINALE IMPEX SRL** with address and tax number **Focsani, Calea Moldovei nr.3, Romania, CUI: RO 5688106.**

After the test, the doors meet the requirements for classification **EI 30**. The protocol numbers to be issued by Fplus are **№ TR-246-01 / 15.05.2020** and **№ CR-246-01 / 20.05.2020.**

General Manager "F plus" Ltd.

Dipl.-eng Plamen Uzunov

FPLUS

31.07.2020